




MODEL NUMBER NOMENCLATURE



OPTIONS: IL (Intake Louver); IH (Intake Hood);
 PF (Prefilter); MG (Mist and Grease Eliminator); FF (Final Filter);
 PH(EorG) (Preheater Electric or Glycol); SWPH (Summer Winter Preheater);
 AC (Packaged Airconditioning or Dehumidification);
 INS (Insulated); DW (Double Wall Construction);
 MB (Multiple Media Beds); PW (Prewired);
 EF (Enclosed fan); RF (Redundant Fans);
 DS (Discharge Silencer)

The model described above is a Packed Bed System, 6' high, 4' wide, one 24" and 12" deep bed chambers, welded 316L stainless steel construction, blow thru application.



SYSTEM DESCRIPTION

The Unisorb Canada PBS SYSTEM is a completely self contained, horizontal airflow package. This deep bed system provides continuous high efficiency air purification for contaminated air streams ranging from 150 to 8,000 CFM.

The Unisorb Canada PBS SYSTEMS come in either BLOWTHRU or DRAWTHRU configurations. Blowthru configurations are generally used for corrosion control applications. Drawthru configurations are generally used for odor control or environmental emission applications.

The standard PBS air purification system includes the following:

CONSTRUCTION

Standard casing construction is 14 gauge all welded stainless steel. 11 gauge aluminum and 14 gauge epoxy coated welded mild steel and FRP options are available to suit specific requirements. An optional insulated and double walled casing is available when required for heat loss or condensation or acoustic purposes. An optional housed blower plenum enclosure is available when requested for noise suppression, unique plenum ducting requirements, or vandalproofing.

PREFILTER SECTION

This section provides prefiltration to protect the downstream system components and media. The 2" deep - 35% MERV 8 prefilter is used for the retention of larger particulates. Optional 95% MERV 14 after filters are available for protection against blinding of the media bed by smaller particulates. Unisorb ultra high efficiency 3 stage Mist and grease prefiltration is used on moist sewage collection and treatment systems.

A magnehelic differential pressure gauge is used to monitor the pressure drop across the prefilter sections to determine when the changeout or cleaning of filters is necessary. An optional photohelic differential pressure gauge/switch is used when a set of contacts is required to provide local monitoring and also to send an alarm signal to a remote location to indicate when the filters need to be checked or changed. A side access door with quick release, snap acting type, positive pressure latches are used for quick, easy access to the filters.



CHEMICAL MEDIA SECTION

This section houses the Unisorb Canada chemical media(s) as selected to suit the specific contaminant control application. PBS units are designed for bulk loading of chemical media. Hatch(es) access is on the top of the unit through quick release, snap acting type, positive pressure latches for immediate access. Gravity unloading is normally accomplished through the media section door(s) on the side of the unit. Vacuum unloader fittings are available for these doors to assist in fast efficient media removal without operator contact when required.

Media and/or air sample ports are provided on each system to assist in retrieving media or air samples for analysis.

Multiple chambers are provided when more than one type of chemical media is required to facilitate removal of different types of contaminants which may be present.

Optional media bed monitors are installed in this section when required to assist in monitoring and tracking the rate of progression of H₂S contaminants through the chemical media bed. This option is useful for the prediction of H₂S contaminant breakthrough for such systems.

Gravity hopper unloading with a dump valve is available when required. In such cases the system is provided with it's own stand to allow access under the hopper.

FINAL FILTER SECTION

This section provides high efficiency particulate filtration to remove any fine dust which may be released from the system during media changeout, or initial startup of the system. The high efficiency 6" deep - 95% MERV 14 final filter is used for the retention of fine particulates to protect the downstream air space.

Extruded aluminum filter tracks with positive air seals are used to prevent air from bypassing around the filters.

A magnehelic differential pressure gauge is used to monitor the pressure drop across the filter section to determine when the changeout of filters is necessary. An optional photohelic differential pressure gauge/switch is used when a set of contacts is required to provide local monitoring and also to send an alarm signal to a remote location to indicate when the filters need to be checked or changed. A side access door with quick release, snap acting type, positive pressure latches are used for quick, easy access to the filters.



BLOWER SECTION

This section contains the blower, motor, and belt drive components to move the appropriate quantity of air through the system. The blower system is designed to overcome the static pressure losses involved with the air purification system and the external system losses. The components are selected to provide reliability for continuous 24 hour, 365 days per year operation in a contaminated environment.

Corrosion resistant pressure blowers are used for most applications. Radial or backward inclined bladed centrifugal blowers are selected for each unique application to ensure an operating point which will allow flexibility for field adjustments should the operating parameters change. Scroll drains, belt guards, and shaft guards are standard on all exposed fan systems. The blower is typically isolated from the remainder of the system for vibration purposes.

Where spark proof or special corrosion resistant construction is required they will be provided.

Standard motors are TEFC. Special explosion proof construction features are available as required to suit field requirements.

The standard unit comes ready for field wiring connections to the electrical box on the motor. Starters, disconnects, controls, and panel lights are all available as required.




STANDARD CONSTRUCTION:

- 14 Gauge Stainless Steel
- 2" Deep - 35% MERV 8 Pre Filter, 6" Deep - 95% MERV 14 Final Filter
- Aluminum Extrusion Filter Tracks
- Structural Steel Base (Epoxy Coated)
- Doors Sealed With Closed Cell Neoprene Gasketing
- ¼ Turn and Snap Acting Positive Pressure Latches
- Blower - TEFC Motor
- Dual Media Beds
- Media Sample Ports
- Magnehelic Gauges for Mist & Grease Eliminator Prefilter Section

OPTIONS:

- ___ Draw Thru Design
- ___ Blow Thru Design
- ___ 11 Gauge Welded Aluminum Unit
- ___ 14 Gauge SS
- ___ FRP Construction
- ___ Insulated Casing
- ___ Double Wall Construction
- ___ Multiple High Capacity Media Chambers
- ___ Intake Louver with Birdscreen
- ___ Intake Gooseneck Hood with Birdscreen
- ___ Mist and Grease Elimination
- ___ Electric SCR Controlled Sheathed Element Preheat Coil
- ___ Cooling or Dehumidification
- ___ Media Bed Vacuum Unloader(s)
- ___ Media Bed Monitor
- ___ Discharge Plenum
- ___ Photohelic Differential Pressure Gauges
- ___ EXP rated pressure switch
- ___ NEMA rated Control Panel, Starter, and Disconnect
- ___ Explosion Proof Motor
- ___ Spark Proof Blower Construction
- ___ Housed Blower Plenum Enclosure
- ___ Redundant Fans
- ___ Summer/Winter Prefilter Heater
- ___ Discharge Silencer
- ___ Other _____



PBS Selection Guide						
SELECTION COLUMN	PBS MODEL NO.	AIR FLOW RANGE (CFM)	MOTOR RANGE (HP)	MEDIA VOLUME (FT ³) *	SHIPPING WEIGHT EMPTY (LBS)	OPERATING WEIGHT (LBS) *
	202	150-400	1-1.5	16	585	1385
	302	240-600	1.5-3	22	655	1755
	402	480-800	1.5-3	28	730	2130
	403	720-1200	3-5	41	815	2865
	404	960-1600	5-7.5	55	905	3655
	504	1200-2000	5-7.5	67	955	4305
	604	1440-2400	7.5-10	80	1080	5080
	605	1800-3000	7.5-10	100	1185	6185
	606	2160-3600	7.5-10	119	1295	7245
	706	2520-4200	10-15	139	1395	8345
	608	2880-4800	10-15	157	1505	9355
	708	3360-5600	10-15	183	1625	10775
	808	3840-6400	10-15	207	1760	12110
	809	4320-7200	15-20	233	1950	13600
	810	4800-8000	15-20	259	2150	15100

*Media Volume and Operating Weights based on typical 3' deep media bed

Specialists in Air & Gas Purification, Corrosion & Odor Control

12944 – 148 STREET, EDMONTON, ALBERTA T5L 2H8 PHONE: (780) 447-1141 FAX: (780) 447-1833



SPECIFICATIONS

1.0 PURPOSE

A Unisorb Canada PBS horizontal deep bed air purification system is to be provided for this application. The system shall be a complete package designed for the removal of all organic and inorganic vapors or gases. The system shall ensure no bypass of contaminants and shall provide a minimum 99.9% removal efficiency of constituent contaminants.

2.0 DESIGN

- 2.1 The manufacturer shall have a minimum of 5 years of history in design, fabrication, and testing of similar air purification systems. The system shall provide a minimum airflow capacity as outlined in the specification parameters.
- 2.2 The air purification system shall have prefilters, chemical media bed(s), final filters, a blower section, and options to suit the specific requirements.
- 2.3 The system shall be configured either in a blow thru or draw thru configuration as suited to the application.
- 2.4 The manufacturer shall guarantee a minimum life expectancy for the system according to the inlet and outlet contaminant levels for this application. Discharge contaminant levels shall not exceed defined parameters at any time before media expiry.
- 2.5 The manufacturer shall have the capability of providing in house laboratory analysis for testing media and air samples to assist in determining media bed consumption rates.
- 2.6 Where corrosion control is involved the equipment manufacturer shall provide corrosion monitoring assistance for the controlled space. In house production and analysis of corrosion coupons shall be provided by the equipment manufacturer.



- 2.7 The chemical media shall have the capability of being unloaded by gravity flow through a hinged unloading door or a vacuum unloader at the bottom side of each media section. Loading shall be accomplished through the removable hatch on top of the unit.
- 2.8 All media beds shall be designed to have a means of obtaining a media and air sample.
- 3.0 CONSTRUCTION AND FABRICATION**
- 3.1 The base frame shall be structural steel epoxy coated channel.
- 3.2 The unit casing shall be welded with similar metals. Any dissimilar metals shall be fastened together by mechanical fasteners.
- 3.3 To produce high quality low distortion welds, the GTAW (TIG) welding process shall be used.
- 3.4 All access doors and hatches shall use closed cell neoprene gasketing to prevent any air leakage.
- 3.5 All gasket material shall be 1/4" thick by 0.75" wide closed cell neoprene foam.
- 3.6 Service doors and all unit access shall be oriented to suit field conditions or requirements.
- 3.7 Hinges shall be of continuous piano type pin, and constructed of 300 series stainless steel. Doors shall be held closed with quick release, snap acting type, positive pressure latches.
- 4.0 INTAKE & PRE-FILTER SECTION**
- 4.1 The intake section shall take into consideration any intake hoods, louvers, birdscreens, flanges, and prefilters to prevent the passage of rain, snow, or particulates into the downstream sections of the air purification system.



- 4.2 Any preheating, cooling, or humidification necessary to temper the incoming air stream shall be provided by the equipment manufacturer.
- 4.3 The prefilter section shall include a 35% MERV 8 roughing prefilter, based on ASHRAE Standard 52.1, and shall carry Class 2 certification in accordance with UL Standard 900. Optional 95% MERV 14 after filter is available.
- 4.4 Filter face velocities and filter resistances shall not exceed the allowances for the project.
- 4.5 Any mist elimination and grease prefilter systems shall be provided when required.
- 4.6 Extruded aluminum particulate filter tracks with positive air seals shall be used to allow easy changing of the filters, and to ensure air does not bypass the filters.
- 4.7 Access doors to the filters shall be with quick release, snap acting type, positive pressure latches.
- 4.8 The prefilter section shall be monitored by a magnehelic differential pressure gauge or a photohelic pressure switch/gauge.

5.0 **CHEMICAL MEDIA**

- 5.1 The chemical media(s) shall be as selected for this application with minimum performance and physical characteristics as defined for the application. Media data sheets, current MSDS information and original samples are to be provided by the manufacturer.
- 5.2 The media bed depth(s), bed volume(s), and residence time(s) shall meet or exceed the minimum requirements.
- 5.3 Media bed face velocities shall not exceed the specified rate for this application.
- 5.4 Media pressure losses shall not exceed the design limitations.



- 5.5 The chemical media shall have the capability of being unloaded by gravity flow through a hinged unloading door or a vacuum unloader at the bottom side of each media section. Loading shall be accomplished through the removable hatch on top of the unit.
- 5.6 All media beds shall be designed to have a means of obtaining a media sample.
- 6.0 **FINAL FILTERS**
- 6.1 The particulate final filter section shall include a 95% MERV 14 high efficiency after filter based on ASHRAE Standard 52.1, and shall carry Class 2 certification in accordance with UL Standard 900.
- 6.2 Filter face velocities and filter resistances shall not exceed the allowances for the project.
- 6.3 Extruded aluminum particulate filter tracks with positive air seals shall be used to allow easy changing of the filters, and to ensure air does not bypass the filters.
- 6.4 Access doors to the filters shall use quick release; snap acting type, positive pressure latches.
- 6.5 The final filter section shall monitor the pressure drop by a magnehelic differential pressure gauge or a photohelic pressure switch/gauge.
- 7.0 **BLOWER SECTION**
- 7.1 Standard blower arrangement shall be configured for a draw thru or blow thru application. The blower shall be an industrial centrifugal type of suitable corrosion resistance construction. Bearings shall be based on L10 minimum life of 40,000 hours of average life of 200,000 hours. Adjustable motor base shall have a two point leveling and tension adjustment.



- 7.2 The blower assembly shall be installed utilizing isolation mounts for vibration purposes.
 - 7.3 Sheaves shall be sized for a minimum of 150% of motor horsepower, fully machined, cast iron, keyed and securely attached to the shaft. The blower shall be driven using heavy industrial adjustable V belts which are oil and heat resistant and non-static conducting.
 - 7.4 The blower section shall have accessibility for maintenance purposes, including balancing, greasing, tachometer (RPM) readings, and scroll drain.
 - 7.5 Shaft and belt guards shall be provided for personnel safety.
 - 7.6 Optional spark proof blower construction shall be provided for such rated environments.
 - 7.7 The motor shall be totally enclosed fan cooled (T.E.F.C.) type rated for the intended duty cycle.
 - 7.8 Optional explosion proof motor construction shall be provided for such rated environments.
 - 7.9 Optional housed blower plenum enclosure shall be provided upon request.
 - 7.10 Optional disconnect, starter, and controls shall be provided as required to suit the application.
- 8.0 **PACKAGING & HANDLING**
- 8.1 The air purification system shall be capable of preventing any deflection during rigging, handling, transportation, operation, or servicing.
 - 8.2 Lifting lugs and/or anchor bolt locations shall be provided for safe handling and operation of the system.